

PLAYGROUND SAFETY INSPECTION

Accessibility to Play Area Worksheet

(Complete one worksheet for each Playground)

*This worksheet only applies to the access ramp into the play area,
All elements of the access route shall comply with
ADA Standards 2010*

Yes	No	N/A	General (ASTM F 1487-11 Section 10) (ADA Standards 2010 - Chapter 4)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The Playground has an access point	
			Accessible Curb Ramp (ADA Standards 2010 - Chapter 4, Section 406)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maximum slope is 1:12 (8.3%) A slope greater than 1:20 (5%) is considered a ramp.	Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The minimum clear width of the curb ramp is 36" exclusive of curbs or side flairs.	Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Ramp has minimum two inch high curbs	Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maximum slope of side flairs is 1:10 (10%)	Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maximum cross slope is 1:48	Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maximum length without handrails is less than 72"	Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Vertical Changes of level under 1/4 inch high maximum are allowed	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Changes in level between 1/4 inch and 1/2 inch are beveled with a slope of less than 1:2	

Priority: Priority 1 Priority 2 Priority 3 Compliant

Comments:
