

PLAYGROUND SAFETY INSPECTION
Ground Level Access Route in Play Area Worksheet
 (Complete one worksheet for each Playground)

Yes	No	N/A	General (ASTM F 1487-11 Section 10) (ADA Standards 2010 - Chapter 10 Section 1008)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The Playground has an access point (See Accessibility to Play Area Worksheet)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Entire use zone of playground is surfaced with an accessible material (<i>not Required</i>)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	If entire use zone is not accessible, at least one route shall be provided from perimeter to all accessible play structures or components.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	When the access and egress points are not the same, an accessible route is provided to each.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Accessible play opportunities with different access and egress points must allow the user the opportunity to return unassisted to the original transfer point.

Ground Level Access Route in Play Area			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maximum Running slope is 1:16 Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maximum cross slope is 1:48 Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Vertical change of level under 1/4 inch high maximum is permitted Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Changes in level between 1/4 inch and 1/2 inch are beveled with a slope of less than 1:2 Actual _____

Width of Accessible Rout (Play Areas that are more than 1000 Square Feet)			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The minimum clear width of the accessibility route within the play area is 60" Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Restricted Minimum width is 24 inches for a distance of 60 inches
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Multiple Restricted Minimum width sections are separated by segments that are 60 inches wide and 60 inches long

Width of Accessible Rout (Play Areas that are less than 1000 Square Feet)			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The minimum clear width of the accessibility route within the play area is 44" Actual _____
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Accessible Routs exceeding 30 feet have at least one turning space that is 60" radius or T shaped
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Restricted Minimum width is 24 inches for a distance of 60 inches
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Multiple Restricted Minimum width sections are separated by segments that are 60 inches wide and 60 inches long

Vertical Clearance			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The vertical clearance of the ground level access route is a minimum of 80"

Handrails			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Handrails are not required for ground level routs in the play area

Priority: Priority 1 Priority 2 Priority 3 Compliant

Comments:
